

Resene Paints (Australia) Limited - Uracryl 402 Clear + Resene Anti Slip Grip Additive Sample - Wet Sliptest AN200624-13

20 Jun 2024

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013

This Test Report Is In Accordance with Appendix A	Wet Pendulum Test
Date Tested:	20 Jun 2024
Test Report Number:	AN200624-13
Client Name & Billing Address:	Resene Paints (Australia) Limited - PO Box 918, Ashmore City, Qld 4214
Surface Tested :	Uracryl 402 Clear + Resene Anti Slip Grip Additive - Sample Applied to 45x60cm MDF Board
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Any Variations to Standards	Variation of Standards only 1 Sample Available for testing
Testing Officer / Approved Signatory:	Alyssa Neill
Pendulum in use - Calibration Date :	#2140 - Munro-Stanley Portable Skid Tester (C : 12.09.23 - EN 13036-4-2011)

Signature of Approved Signatory :

Test Results : (Samples and Test Information Supplied by Client)

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN	SCV :	Surface Picture
1A	55	55	55	55	55	55	N/A	
1B	68	68	65	65	65	65	N/A	
1C	58	58	57	57	57	57	N/A	
1D	55	55	55	55	55	55	N/A	
1E	57	57	57	56	56	56	N/A	

Reported SRV For Test Area : 58

CLASSIFICATION using Slider 96 (4S Slider) P5 = > 54

Declaration: The factual matters stated within this report are, to the best of my knowledge, true and correct. I have completed all enquiries that I consider appropriate in formulating my conclusions. The opinions stated by me within this report are genuinely held by me. The report contains reference to all matter which I regard as significant. I understand that my overriding duty as an expert is to assist the Court and have complied with this duty. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Any enquiries in relation to this report should be directed to Sliptest Australia Pty. Ltd. quoting the applicable test report number. Accredited for Compliance with ISO/IEC 17025. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials & AS 4663:2013 Classification of existing pedestrian surface materials - Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014. This report and covering documentation was prepared by SliptestAustralia Pty. Ltd. on behalf of our client as named in the report. Neither Sliptest Australia Pty. Ltd. nor any person acting on our behalf (a) makes any warranty, express or implied, with respect to the use of any information or methods disclosed in this report or (b) assumes any liability with respect to the use of any information or methods disclosed in this report or covering information. Any recipient of this

document, by their acceptance or use of this document, releases Sliptest Australia Pty. Ltd. and their affiliates from any liability for direct, indirect, consequential or special loss or damage whether arising in contract, warranty, express or implied, tort or otherwise, and irrespective of fault, negligence and strict liability.